



ENGINEERING AND RESOURCE PROTECTION REVIEW COMMENTS

Busch Gardens Trapper Restroom

COUNTY PLAN NO. SP-058-13

July 5, 2013

General:

1. A Land-Disturbing Permit and Siltation Agreement, with surety, are required for this project.
2. VSMP. It appears disturbed area for the site exceeds 2,500 square feet. Therefore, it is the owner's responsibility to register for coverage under the General Permit for Discharge of Stormwater from Construction Activities, in accordance with current requirements of the Virginia Department of Conservation and Recreation and the Virginia Stormwater Management Program. Visit <http://www.dcr.virginia.gov/sw/vsmp.htm> or contact the DCR Central Office at 804-371-7330 for additional information. (Note: Evidence of VSMP registration will be required by the County prior to or concurrently with a preconstruction meeting and must be provided prior to issuance of a local land-disturbing permit and start of land-disturbing activities.)

Erosion & Sediment Control Plan:

3. Standard E&SC Notes. Replace the Erosion Control Notes on {List Sheet} with revised James City County, Engineering and Resource Protection Division, standard Erosion and Sediment Control Notes dated 10/01/09. Contact the Division at 757-253-6670 if you need a hard or electronic copy of the standard notes.
4. E&SC Narrative. Provide a brief erosion and sediment control plan narrative in accordance with VESCH requirements. The narrative should include important site, adjacent parcel, soil and development information as well as specific control and stabilization measures as proposed.